



Established 1868

1045 West Shore Road, Pelee Island, Ontario, Canada N0R 1M0
Telephone: 519-724-2931 \ Toll Free: 1-866-889-5203 \ Fax: 519-724-2470
Email: info@pelee.ca \ Website: www.pelee.org

**Annual Performance Report
Pelee West Shore Water System
Drinking Water System # 220008177**

2019

Prepared for the Municipality of Pelee Island
By the Ontario Clean Water Agency
Submitted February 27, 2020

The Corporation of the Township of Pelee is required to provide an Annual Report for its Ministry of the Environment Regulated Drinking Water System (DWS) under *Drinking Water Systems Regulation O. Reg. 170/03* in accordance with the *Safe Drinking Water Act* (as amended). The purpose of this letter and its attachments is to satisfy this requirement and report the dates from January 1, 2019 until December 31, 2019.

The Township of Pelee owns and operates the Pelee West Shore Water System, which is a Non - Class Water Treatment and Distribution System serving a Designated Facility having a DWS Registration Number 220008177. The Pelee West Shore Water System operates under *Ontario Regulation 170/03*. The Pelee West Shore Water System supplies one additional drinking water system within the Township; Pelee East Shore Distribution receives its water via tanker truck from the Pelee West Shore Water System. There was a “Notice of Adverse Test Results” due to loss of water in the East Shore Distribution system in August 2019. A cautionary boil water advisory was put in place. This Report outlines the sampling and direct connections to the Pelee West Shore Water System.

The Pelee West Shore Water System is designated as a Small-Municipal, Non-Residential DWS and serves a population of 7; having 4 residential connections and 1 designated facility. There are 18 total service connections. The Pelee West Shore Well Supply System utilizes Ultra-Membrane Filtration, Ultraviolet Light and Sodium Hypochlorite (12% solution) Injection as its methods of treatment. The Treatment System utilizes continuous monitors for Turbidity, Chlorine, Temperature, PH and Ultraviolet Dose to monitor the water entering, being treated, and sent to the Distribution System. The Pelee West Shore Water System does not include Fluoridation in its process. Since upgraded in 2015 the system utilizes a summer and Winter Mode of operation. Summer operations included the utilization of the 140m³ Standpipe Storage Tank. Winter operation included utilizing in-plant storage only.

Under *Schedule 9 of the Drinking Water Systems Regulation O. Reg. 170/03*, the Township of Pelee is required to detail the distribution grab samples and treatment operation continuous samples in this Annual Report. Elevated finished water turbidity from continuous monitoring was recorded during maintenance and flushing activities within the Plant. These results are listed below in Table 1.

Table 1
Schedule 9 Sampling Results
January 1, 2019 – December 31, 2019

Analysis	Distribution (Grab Sample)		Treated (Continuous Sample)	
	#	Min – Max	# taken	Min – Max
Free Chlorine (mg/L)	104	0.50 – 2.39	Every 2 min	0.005 – 5.01
Turbidity (NTU)	N/A	N/A	Every 2 min	0.022 – 0.034

mg/L- milligrams per liter

NTU – Nephelometric Turbidity Units

N/A - Not applicable

Note – Continuous Samples taken from SCADA monitoring data

Under *Schedule 12 of the Drinking Water Systems Regulation O. Reg. 170/03* the Township of Pelee is required to complete Microbiological Testing of its Raw Intake, Treatment and Distribution Systems. Table 2 outlines these Analytical Results.

Table 2
Schedule 12 Sampling Results
January 1, 2019 – December 31, 2019

Sample Type	# of Samples	Range of E. Coli Results min # – max #	Range of Total Coliform Results min # – max #
Raw	12	0 – <10	0 - 60
Treated	12	0 – 0	0 – 0
Distribution	12	0 – 0	0 – 0

Note – All results in CFU's (Colony Forming Units)

The Township of Pelee is also required to take Treatment and Distribution samples for various Inorganic Parameters under the *Drinking Water Systems Regulation O. Reg. 170/03, Schedule 6-1.1 (4), Schedule 23 and Schedule 24*. The Inorganic Parameter for Nitrate and Nitrite Samples are required to be taken quarterly or not longer than 120 days between sampling. A total of four (4) Nitrate and Nitrite were taken for the purpose of this Report complying with the Sampling Program. Tables 3, 4 & 5 outline these Analytical Results.

Table 3
Distribution Inorganic Sampling Completed
January 1, 2019 – December 31, 2019

Parameter	Sample Date	Results	Unit of Measure	Exceedance
Nitrate	February 13	0.7	mg/L	No
	May 13	0.6	mg/L	No
	August 12	0.4	mg/L	No
	November 12	0.1	mg/L	No
Nitrite	February 13	<0.1	mg/L	No
	May 13	<0.1	mg/L	No
	August 12	<0.1	mg/L	No
	November 12	<0.1	mg/L	No
Nitrate + Nitrite	February 13	0.7	mg/L	No
	May 13	0.6	mg/L	No
	August 12	0.4	mg/L	No
	November 12	0.1	mg/L	No

Table 4
Summary of Inorganic parameters sampled during this reporting period
January 1, 2019 – December 31, 2019

Treated Water	Sample Date	Sample Result	MAC	No. of Exceedances	
				MAC	1/2 MAC
Antimony: Sb (ug/L)	2019/08/12	0.0001	6.0	No	No
Arsenic: As (ug/L)	2019/08/12	0.0004	10.0	No	No
Barium: Ba (ug/L)	2019/08/12	0.037	1000.0	No	No
Boron: B (ug/L)	2019/08/12	0.016	5000.0	No	No
Cadmium: Cd (ug/L)	2019/08/12	<0.000015	5.0	No	No
Chromium: Cr (ug/L)	2019/08/12	<0.002	50.0	No	No
Mercury: Hg (ug/L)	2019/08/12	<0.00002	1.0	No	No
Selenium: Se (ug/L)	2019/08/12	<0.001	50.0	No	No
Uranium: U (ug/L)	2019/08/12	0.00045	20.0	No	No

Table 5
Summary of Organic parameters sampled during this reporting period
January 1, 2019 – December 31, 2019

Treated Water	Sample Date	Sample Result	MAC	Exceedances	
				MAC	1/2 MAC
Alachlor (ug/L)	2019/08/12	<0.3	5.00	No	No
Atrazine + N-dealkylated metabolites (ug/L)	2019/08/12	<0.5	5.00	No	No
Azinphos-methyl (ug/L)	2019/08/12	<1	20.00	No	No
Benzene (ug/L)	2019/08/12	<0.5	1.00	No	No
Benzo(a)pyrene (ug/L)	2019/08/12	<0.005	0.01	No	No
Bromoxynil (ug/L)	2019/08/12	<0.5	5.00	No	No
Carbaryl (ug/L)	2019/08/12	<3	90.00	No	No
Carbofuran (ug/L)	2019/08/12	<1	90.00	No	No
Carbon Tetrachloride (ug/L)	2019/08/12	<0.2	2.00	No	No
Chlorpyrifos (ug/L)	2019/08/12	<0.5	90.00	No	No
Diazinon (ug/L)	2019/08/12	<1	20.00	No	No
Dicamba (ug/L)	2019/08/12	<10	120.0	No	No
1,2-Dichlorobenzene (ug/L)	2019/08/12	<0.5	200.0	No	No
1,4-Dichlorobenzene (ug/L)	2019/08/12	<0.5	5.00	No	No
1,2-Dichloroethane (ug/L)	2019/08/12	<0.5	5.00	No	No
1,1-Dichloroethylene (ug/L)	2019/08/12	<0.5	14.00	No	No
Dichloromethane (Methylene Chloride) (ug/L)	2019/08/12	<5	50.00	No	No
2,4-Dichlorophenol (ug/L)	2019/08/12	<0.1	900.0	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L)	2019/08/12	<10	100.0	No	No
Diclofop-methyl (ug/L)	2019/08/12	<0.9	9.00	No	No
Dimethoate (ug/L)	2019/08/12	<1	20.00	No	No
Diquat (ug/L)	2019/08/12	<5	70.00	No	No
Diuron (ug/L)	2019/08/12	<5	150.0	No	No
Glyphosate (ug/L)	2019/08/12	<25	280.0	No	No
Malathion (ug/L)	2019/08/12	<5	190.0	No	No
Metolachlor (ug/L)	2019/08/12	<3	50.00	No	No

Metribuzin (ug/L)	2019/08/12	<3	80.00	No	No
Monochlorobenzene (Chlorobenzene) (ug/L)	2019/08/12	<0.5	80.00	No	No
Paraquat (ug/L)	2019/08/12	<1	10.00	No	No
Pentachlorophenol (ug/L)	2019/08/12	<0.1	60.00	No	No
Phorate (ug/L)	2019/08/12	<0.3	2.00	No	No
Picloram (ug/L)	2019/08/12	<20	190.0	No	No
Prometryne (ug/L)	2019/08/12	<0.1	1.00	No	No
Simazine (ug/L)	2019/08/12	<0.5	10.00	No	No
Terbufos (ug/L)	2019/08/12	<0.3	1.00	No	No
Tetrachloroethylene (ug/L)	2019/08/12	<0.5	10.00	No	No
Trichloroethylene (ug/L)	2019/08/12	<0.5	5.00	No	No
Vinyl Chloride (ug/L)	2019/08/12	<0.2	1.00	No	No

Under the document, *Procedures for Disinfection of Drinking Water in Ontario*, the Ultra-Membrane Filters Utilized at the WTP must operate within specified Turbidity Effluent Criteria to be considered for disinfection. The filters must produce water with a turbidity not exceeding 0.10 at least 99% of their run time. In Table 6, the Monthly Average Turbidity Effluent has been tabulated.

Table 6
Ultra-Membrane Filter Effluent Turbidity Monthly Averages
January 1, 2019 – December 31, 2019

Month	Average (NTU)	Annual Average
January	0.022	0.027
February	0.023	
March	0.025	
April	0.023	
May	0.027	
June	0.033	
July	0.033	
August	0.028	
September	0.034	
October	0.027	
November	0.023	
December	0.023	

NTU – Nephelometric Turbidity Units

Summary of Lead Testing under Schedule 15.2-2 (1) during this reporting period
 (Applicable to Small non-municipal non-residential systems)

Location - Type	# of Samples	Results (ug/L)	MAC (ug/L)	No. Exceeded
Distribution Water – Lead	1	0.43	10	0

Major expenses required to install, repair or replace drinking water system components

- | | |
|-------------------------------|------------|
| 1. Turbidity meter repairs | \$2,182.71 |
| 2. Submersible pump repairs | \$1,478.04 |
| 3. Truck fill station repairs | \$1,800.00 |